

**CODE / INTERPRETATION / POLICY MATTERS: None**

**OTHER:**

**17) DISCUSSION REGARDING NEWTON HIGH SCHOOL**

It is noted Mr. Harold recused himself. Joe Peluso and Scott Padden testified regarding the site visit. Ground around piping is crushed tar, the appropriateness for this type of installation is in question. There was very poor workmanship at this location which means the installed system has a likelihood of failure. While going through the blueprints it was noticed that there was an outside grease interceptor. All of the outside piping after 10' was installed by unlicensed individuals. There is no gas trap or floor drains for the automotive shop. Mr. Peluso stated that complaints have been filed against the General Contractor and the Vanderweil Engineer. A Staff Assignment is yet to be issued to the Town of Needham.

**MOTION TO DENY VARIANCE REQUEST FROM 10-07-09** by Mr. Hanley, seconded by Mr. Carter

**OPPOSED** None **ABSTAINED** None **RECUSED** Mr. Harold **MOTION CARRIED**

**CONDITIONS:** Board staff will inform the local inspectors of additional violations, adherence to Massachusetts law and Board regulations are a priority.

**ADJOURNMENT:**

**MOTION TO ADJOURN** by Mr. Hanley, seconded by Mr. Kaldas **MOTION CARRIED**