



CITY OF NORWICH
CONNECTICUT

DEPARTMENT OF BUILDING INSPECTION

CITY HALL ANNEX
NORWICH, CONN.

October 5, 1984

Peach Tree Limited Partnership
c/o Colonial Realty Company
P. O. Box 764
Old Saybrook, Ct. 06475

ATTN: Pay Demay

RE: Prop. at Westledge Drive
Norwich, Ct. 06360

Ms. Demay:

An inspection of the property located at Westledge Drive, Norwich, revealed that the required fire separation as listed on Building Permit #111 (copy is attached), and prescribed in Section 875, Article 875.6 of the Basic Building Code, were not installed during the construction of the new pitched roofs. These noted fire walls must be installed prior to the completion of construction.

Also note that any interior repairs can be made only after obtaining building permits, pursuant to Section 122.2 of the Basic Building Code.

Your compliance in this matter is required.


Chris A. Hempstead
Assistant Building Inspector

cf